

# SUTHERLAND CREEK WATERWORKS DISTRICT

## SUTHERLAND CREEK WATERWORKS DISTRICT BY LAW NO. 6

The Trustees of SUTHERLAND CREEK WATERWORKS DISTRICT enact as follows:

1. Where any property owner within the District proposes to use water from the District's system he shall make formal application in writing to the District.
2. Subject to any provision of the "Subdivision Water Regulation and Capital Development Charge Bylaw," the Trustees may approve the application for connection and the Trustees may specify the size, type, position and any other feature of the proposed service pipe installation.
3. It shall be lawful for the Trustees or their representative to enter upon any property within the District for the purpose of inspecting the water service installation therein.
4. The property owner shall be responsible for installation of the service pipe from the outlet of the stop up to and including the household or other system supplied.
5. All service pipes, including those inside the buildings, subject to the direct water pressure from the district's system, shall be of copper, galvanized or plastic pipe to approved waterworks standards and of a recommended operating pressure rating of not less than 160 pounds per square inch, except where otherwise authorized in writing by the District.
6. All buried service pipes shall have a minimum earth cover of five feet, measured from the top of the pipe to the normal ground surface adjacent to the pipe trench, except that in special cases minor deviation from this standard may be permitted by the Trustees in writing.
7. All buried service pipes shall be located in such a manner as to provide ease of access for repair.
8. The District may refuse a water connection to any property the internal plumbing for which does not meet the current specifications laid down in the National Building Code of Canada, or which does not conform to any other conditions which may be required by the Trustees.

9. All plumbing installations shall be inspected by the District, whose written final approval is necessary before connection to the District's system is made.
10. The property owner shall be responsible for the safekeeping of any part of the service connection which is located on his property, and shall keep the meter and valve box covers free from any material or structure which would impede easy access.
11. No controlling stop or other fitting of the District shall be operated by anyone but the authorized agents of the District.
12. Every person who disobeys or fails to comply with any provision of this bylaw shall be guilty of an offence and liable on summary conviction to a penalty of not exceeding Two Hundred Dollars, and in default of payment thereof to imprisonment not exceeding thirty days.

**CITATION:**

13. This Bylaw may be cited as the "Installation Standards Control Bylaw."

Introduced and given first reading by the Trustees the 30<sup>th</sup> day of November 1974.

Reconsidered and passed the 30<sup>th</sup> day of November, 1974.

Signature on file  
Chairman of the Trustees

Signature on File  
Secretary to the Trustees

I hereby certify under the seal of Sutherland Creek Waterworks District that this is a true copy of By-law No. 6 of Sutherland Creek Waterworks District, passed by the Trustees on the 30<sup>th</sup> day of November, 1974.

Signature on File  
Secretary to the Trustee

REGISTERED ON THE 8<sup>TH</sup> DAY OF JANUARY 1975